



Attestation of Conformity

ISO/IEC, EN & TIA/EIA Unscreened Class E / Category 6 Two Connector Permanent Link

**Optronics Ltd.
Davy Avenue
Milton Keynes MK5 8ND, UK**

Attestation of Conformity No. 108583

This type of Class E / Category 6 unscreened two connector permanent link has been tested by 3P Third Party Testing and complies with Class E Permanent link requirements of 2nd Edition ISO/IEC 11801 and CENELEC EN 50173-1:2007, and Category 6 permanent link requirements of ANSI/TIA/EIA-568-B.2-1. The Attestation of Conformity is valid for the actually tested permanent link samples in T568A designation and consisting of the following components:

Cables from Optronics:

*Horizontal Cable,
Qualification Status:*

*P/N UTP6305LSZH
Manufacturer Verified*

Conn. Hardw. from Optronics:

*Keystone Jack,
Patch pannel for
Keystone Jack,
Qualification Status:*

*P/N CAT6JACK,
P/N PANEL24KEystone
Manufacturer Verified*

Patch Cord from Optronics:

*Patch Cord,
Qualification Status:*

*P/N UTP6+PL-C
Manufacturer Verified*

Hoersholm, 10th November 2008

Hoersholm, 10th November 2008

Ole Lambertsen

Ole Lambertsen
Test Responsible

Paul Villien

Poul Villien
Coordinating Manager